

October 10, 2018

Mr. Gary Delger  
Caledonia Community Schools  
8944 Kraft Ave  
Caledonia, MI 49316

RE: Cal Elementary

Dear Mr. Gary Delger:

Prein&Newhof Laboratory received 2 sample(s) on 10/5/2018 for the analyses presented in the following report.

All of the regulated parameters have been analyzed using EPA approved methods.

We are certified by the State of Michigan for drinking water analysis for: Coliform Bacteria, Metals, Cyanide, Minerals, Anions, Volatile Organics, THM's, Haloacetic Acids, and PNA's.

Michigan Lab ID#: 0020  
EPA Lab #: MI000014

Analytes received and/or analyzed out of holding times are noted by a "H" in the Qual field.

Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL) and less than the Reporting Limit (PQL).

Any analyte that exceeds the EPA Maximum Contaminant Level are noted on the report with an "\*" in the Qual field.

The sample results associated with the attached report meet the safe drinking water criteria for the analytes reported unless indicated by a "\*" in the Qual field.



Steve Bylsma  
Laboratory Manager

<b>CLIENT:</b>	Caledonia Community Schools	<b>Lab Order:</b>	1810298
<b>Project:</b>	Cal Elementary		

<b>Lab ID:</b>	1810298-01	<b>Matrix:</b>	DRINKING WATER	<b>Collection Date:</b> 10/4/2018 8:23:00 AM
<b>Client ID:</b>	Room #4 Sink	<b>Sampler:</b>	S. Horka	<b>Received Date:</b> 10/5/2018 9:40:00 AM

Analyses	Result	PQL	Qual	Units	MCL	Date Analyzed
<b>COPPER, DRINKING WATER</b>					<b>EPA 200.7</b>	Analyst: <b>SB</b>
Copper	1.15	0.0100		mg/L	1.30	10/9/2018 12:30:00 P
<b>LEAD, DRINKING WATER</b>					<b>SM 3113B</b>	Analyst: <b>SB</b>
Lead	0.00869	0.00300		mg/L	0.0150	10/9/2018 9:28:35 AM

<b>Lab ID:</b>	1810298-02	<b>Matrix:</b>	DRINKING WATER	<b>Collection Date:</b> 10/4/2018 8:30:00 AM
<b>Client ID:</b>	Room #25 Sink	<b>Sampler:</b>	S. Horka	<b>Received Date:</b> 10/5/2018 9:40:00 AM

Analyses	Result	PQL	Qual	Units	MCL	Date Analyzed
<b>COPPER, DRINKING WATER</b>					<b>EPA 200.7</b>	Analyst: <b>SB</b>
Copper	0.713	0.0100		mg/L	1.30	10/9/2018 12:30:00 P
<b>LEAD, DRINKING WATER</b>					<b>SM 3113B</b>	Analyst: <b>SB</b>
Lead	< 0.00300	0.00300		mg/L	0.0150	10/9/2018 9:28:35 AM

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level.	< Not Detected at the Reporting Limit	
	D Dilution was required.	H Holding times for preparation or analysis exceeded	
	J Analyte detected below quantitation limits	MCL Maximum Contaminant Level	
	PL Permit Limit	PQL Practical Quantitation Limit	Original